

**PUBLIC SAFETY RADIO SIGNAL BOOSTER SYSTEM  
(a/k/a) Bi-Directional Amplifier System (BDA)**

**REQUEST FOR QUOTATION**

**ADDENDUM NUMBER: THREE (3)**

**NOVEMBER 29, 2017**

**THIS ADDENDUM IS ISSUED PRIOR TO THE ACCEPTANCE OF THE FORMAL RFQ's. THE FOLLOWING CLARIFICATIONS, AMENDMENTS, ADDITIONS, DELETIONS, REVISIONS, AND MODIFICATION FORM A PART OF THE CONTRACT DOCUMENTS ONLY IN THE MANNER AND TO THE EXTENT STATED.**

Correction to Addendum Two - Please note emergency power is available at each Hospital therefore a **four (4) hour** backup requirement will prevail.

**END ADDENDUM THREE**