

ROOF RESTORATION FOR CORA E. BRAYNON FAMILY HEALTH CENTER RFQ**REQUEST FOR QUOTATION****ADDENDUM NUMBER: ONE****AUGUST 16, 2019**

THIS ADDENDUM IS ISSUED PRIOR TO THE ACCEPTANCE OF THE FORMAL RFQ'S. THE FOLLOWING CLARIFICATIONS, AMENDMENTS, ADDITIONS, DELETIONS, REVISIONS, AND MODIFICATION FORM A PART OF THE CONTRACT DOCUMENTS ONLY IN THE MANNER AND TO THE EXTENT STATED.

Q&A

1. Is it possible to consider a different paint manufacturer? **Alternate product must have the same or better specifications and warranty of the product specified. Any substitution must be approved by Architect of record before award.**
2. For the ceiling paint, what warranty do you require? **Review specifications in document, ceiling paint is not required.**
3. Is it necessary to lift the wiring from the lightning rod to paint or can the wiring be painted over? **Lightning protection must not be painted over and should be protected. Incidental paint on a small section would be acceptable.**
4. Have any leaks been detected on the roof? **There have been small leaks in the past and were quickly repaired. Currently there are no known leaks in the area referenced in the RFP.**

END ADDENDUM ONE